

Letter :- 112 Dated - 05/03/2025

Government of Bihar
Public Health Engineering Department
Monthly Water Quality Monitoring Report

DISTRICT :- VAISHALI

DIVISION - HAJIPUR

Sample Collected by:- School staff

Month:- March, 2025

Sl No	Block	Panchayat	Village	Name of Habitation	Location of Source	Parameters														Report Handed Over to Beneficiary Or not	Format: I	
						pH	Turb.	EC	TDS	TH	Ca	Mg	Cl	AL	Fe	NO3	SO4	F	As	Total Coll	Remarks	Remarks
1	Bidupur			Shitalpur Kamalpur Bidupur Hajipur	Happy Mind Academy	7.1	1.0	273	155	109	25	11	23	119	-	-	-	0.1	-	-ve		
						6.5-8.5	1.0	-	500	200	75	30	250	200	0.3	45	200	1.0	0.01	-	-	-
Permissible Limit* in absence of alternative source						NR	5.0	-	2000	800	200	100	1000	500	1.0	NR	400	1.5	NR	-	-	-
						unit	-	NTU	m/s	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l			

CPB 05/03/25
Lab Assistant
PH Division Hajipur

Chemist 05/03/25
PH Division Hajipur

Preeti Singh
Principal
HAPPY MIND ACADEMY
BIDUPUR (VAISHALI)

Minal Kshi
Manager
HAPPY MIND ACADEMY
BIDUPUR (VAISHALI)